- १. उपरी तारमार्गांच्या वीज संचमांडणीचे नकाशे मंजरू करणे (त्रुटी नसल्यास अथवा त्रुटीच्या पूर्ततेनंतर) विद्युत अधिनियम, 2003 (2003 चा 36)अन्वये तयार करण्यात आलेले केंद्रीय विद्युत प्राधिकरण (विद्युत पुरवठा व सुरक्षा संबंधित उपाययोजना) विनियम, 2010 मधील विनियम क्र. ४३ नुसार-
 - 3) मालक / विहवाददार यांनी सादर केलेल्या सिवस्तर योजनेला आपले महाऑनलाईन पोर्टल च्या माध्यमातून ऑनलाइनअर्ज व विहित शुल्क प्राप्त झाल्यावर विद्युत निरीक्षक मान्यता देतील. काही आक्षेप असल्यास ते मालक / विहवाददार यांना कळविण्यात येतील.
 - ब) आक्षेपांची पूर्तता करून सविस्तर योजना पुन्हा सादर झाल्यावर त्यास विद्युत निरिक्षकाद्वारे मान्यता

देण्यात येईल.

लोकसेवाचा तपशील	पदनिर्देशित अधिकारी (लोकसेवा देणारा)	लोकसेवा पुरिवण्यासाठी विहीत केलेली कालमर्यादा (कामाचेदिवस)	लोकसेवा पुरिवण्यासाठी विहीत केलेली माध्यम
(अ) 650 व्होल्ट वरील ते 33 के.व्ही. पर्यंत	विद्युत निरीक्षक	तीस दिवस	महाऑनलाईन पोर्टल वर उद्योग, उर्जा व कामगार विभागाच्या उर्जा विभागाद्वारे देण्यात येणारी ऑनलाइन सेवा
(आ) 33 के.व्ही. वरील ते 220 के.व्ही.पर्यंत	अधीक्षक अभियंता	तीस दिवस	वरीलप्रमाणे
(इ) 220 के.व्ही. वरील	मुख्य विद्युत निरीक्षक	तीस दिवस	वरीलप्रमाणे

.....

- 1. Approval for plan of Electrical Installation with overhead lines (No defects or after compliance of defects) under regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 framed under the Electricity Act,2003 (36 of 2003) for,
 - i) Approval to the plan for submitted by owner/occupier/supplier is to be accorded by electrical inspector on receipt of online application and the payment of prescribed fees at Mahaonline Portal. Shortcomings if any shall be conveyed to the concerned.
 - ii) On resubmission on plan after compliance of defects observed the same is to be approved by the Electrical Inspector.

Name of the Public Service	Designated Officer by whom services will be provided	Time limit for providing service (working days)	Mode of providing service
(a) above 650 Volt to 33 KV	Electrical Inspector	Thirty days	Online service of Energy Deptt. Under Industry, Energy and Labour Deptt. on Mahaonline Portal
(b) above 33 KV to 220 KV	Superintending Engineer	Thirty days	As above
(c) above 220 KV	Chief Electrical Inspector	Thirty days	As above